

Energy Report Summary for February 2011

Prepared for:



Natural Resources
Canada

Ressources Naturelles
Canada

Canada

Prepared by:



*Science Applications International Corporation
(SAIC Canada)*


February 22, 2012
Document Version 3.0
CM002171

PROPRIETARY

Drake Landing Solar Community Energy Overview for February 2011

This document summarizes the energy generated and used within the Drake Landing Solar Community at Okotoks Alberta.

Additional Information may be found here: <http://www.dlsc.ca>



System Energy Diagram

Table 0-1 Summary for February 2011				
Description	This Month		Since July 1, 2010	
Total Incident Solar Energy	851.9	GJ	7412.2	GJ
Total Solar Energy Collected	228.9	GJ	2279.7	GJ
Total Solar Energy Delivered to STTS	222.2	GJ	2195.6	GJ
Total Energy Delivered to BTES	0.0	GJ	1241.2	GJ
Total Energy Extracted from BTES	146.7	GJ	1067.7	GJ
Total Energy Delivered from STTS to HX-2	389.9	GJ	1966.2	GJ
Total Solar Energy Delivered to District Loop	358.8	GJ	1785.3	GJ
Natural Gas Energy Used	117.2	GJ	332.1	GJ
Boiler Thermal Energy Delivered to the District Loop	115.7	GJ	320.4	GJ
Total Energy Delivered to District Loop	474.6	GJ	2105.8	GJ
Average Solar Collector Efficiency	27	%	31	%
Average Efficiency of HX-1	97	%	96	%
Average Efficiency of HX-2	92	%	91	%
Average BTES core temperature	44.0	°C	55.3	°C
Electrical energy used	15.7	GJ	81.1	GJ
PV energy generated	0.5012	GJ	6.6	GJ
Net change in energy stored in STTS	-4.81	GJ	-39.9	GJ
Solar Fraction	76	%	85	%