



Energy Report Summary for October 2014

Prepared for:



Natural Resources
Canada

Ressources Naturelles
Canada

Canada

Prepared by:



leidos



*Leidos Canada
(Formerly SAIC Canada)*


December 16, 2014
Document Version 1.0
CM002171

PROPRIETARY

Drake Landing Solar Community Energy Overview for October 2014

This document summarizes the energy generated and used within the Drake Landing Solar Community at Okotoks Alberta.

Additional Information may be found here: <http://www.dlsc.ca>



System Energy Diagram

Table 0-1 Summary for October 2014		
Description	This Month	Since July 1, 2014
Total Incident Solar Energy	1048.9 GJ	4854.5 GJ
Total Solar Energy Collected	339.6 GJ	1794.3 GJ
Total Solar Energy Delivered to STTS	333.4 GJ	1839.1 GJ
Total Energy Delivered to BTES	191.7 GJ	1381.1 GJ
Total Energy Extracted from BTES	0.1 GJ	0.1 GJ
Total Energy Delivered from STTS to HX-2	133.1 GJ	271.9 GJ
Total Solar Energy Delivered to District Loop	122.0 GJ	246.4 GJ
Natural Gas Energy Used	0.0 GJ ¹	0.0 GJ
Boiler Thermal Energy Delivered to the District Loop	0.0 GJ	0.0 GJ
Total Energy Delivered to District Loop	122.0 GJ	246.4 GJ
Average Solar Collector Efficiency	32 %	37 %
Average Efficiency of HX-1	98 %	102 %
Average Efficiency of HX-2	92 %	91 %
Average BTES core temperature	59.6 °C	58.8 °C
Electrical energy used	6.0 GJ ²	17.5 GJ ³
PV energy generated	4.9442 GJ	31.8 GJ
Net change in energy stored in STTS	8.7 GJ	250.2 GJ
Solar Fraction	100.0 %	100.0 %

¹ Gas consumption is reported during monthly maintenance inspections which may not coincide with the reporting period. The reported gas consumption is for the period between October 6, and November 12, 2014

² The electrical energy consumption is reported during monthly maintenance inspections which may not coincide with the reporting period. The reported gas consumption is for the period between October 6, and November 12, 2014.

³ Since June 26, 2014.